

## DETAILS OF CLIENT/LANDLORD

Client/  
Address:The [Showman.com](http://Showman.com). 1 Square Close. Station Road. Cullompton. Devon.  
E15 1BQ.

## TEST EQUIPMENT DETAILS

Test Equipment used Megger Pat4 DV3

Serial Number 6410-922/080108/83

Tested by Roger Dyer

Test Date

10.07.25

Retest Date

10.07.26

ID Number	Description	Location	Voltage (V)	Rating (W)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use?
1732	USB ADAPTOR	MOBILE	230	—	—	✓	N/A	✓	✓
1733	EXT LEAD	"	"	13AMP	13	✓	✓	✓	✓
1734	EXT LEAD	"	"	13AMP	13	✓	✓	✓	✓
1735	EXT REEL	"	"	3120	13	✓	✓	✓	✓
1736	POWER SUPPLY	"	"	<320	3	✓	N/A	✓	✓
1737	POWER SUPPLY	"	"	—	—	✓	N/A	✓	✓
1738	POWER SUPPLY	"	"	—	—	✓	N/A	✓	✓
1739	USB ADAPTOR	"	"	96	3	✓	N/A	✓	✓
1740	POWER SUPPLY	"	"	<320	3	✓	N/A	✓	✓
1741	MIXER	"	"	<1200	13	✓	✓	✓	✓
1742	POWER LEAD	"	"	<1200	13	✓	✓	✓	✓
1743	SPEAKER	"	"	<1200	13	✓	✓	✓	✓
1744	POWER LEAD	"	"	<720	5	✓	✓	✓	✓
1745	EXT LEAD	"	"	13AMP	13	✓	✓	✓	✓
1746	SPEAKER	"	"	<720	5	✓	✓	✓	✓
1747	USB ADAPTOR	"	"	—	—	✓	N/A	✓	✓
1748	USB ADAPTOR	"	"	—	—	✓	N/A	✓	✓
1749	USB ADAPTOR	"	"	—	—	✓	N/A	✓	✓
1750	POWER LEAD	"	"	<1200	13	✓	✓	✓	✓
1751	SPEAKER	"	"	<1200	13	✓	✓	✓	✓
1752	SPEAKER	"	"	<1200	13	✓	✓	✓	✓
*									